

INDEX

REBUTTAL TESTIMONY OF

FRANCIS R. PUYLEART, ELIZABETH A. KIRBY, AND BARTHOLOMEW A. MCMANUS

Witnesses for Bonneville Power Administration

SUBJECT:	GENERATION INPUTS BALANCING RESERVE FORECAST	Page
Section 1:	Introduction and Purpose	1
Section 2:	Balancing Reserve Quantity Capacity Forecast.....	1

This page intentionally left blank.

REBUTTAL TESTIMONY OF

FRANCIS R. PUYLEART, ELIZABETH A. KIRBY, AND BARTHOLOMEW A. MCMANUS

Witnesses for Bonneville Power Administration

SUBJECT: GENERATION INPUTS BALANCING RESERVE FORECAST

Section 1: Introduction and Purpose

Q. Please state your names and qualifications.

A. My name is Francis R. Puyleart, and my qualifications are contained in BP-22-Q-BPA-30.

A. My name is Elizabeth A. Kirby, and my qualifications are contained in BP-22-Q-BPA-19.

A. My name is Bartholomew A. McManus, and my qualifications are contained in
BP-22-Q-BPA-45.

Q. Please state the purpose of your testimony.

A. The purpose of our testimony is to respond to the Direct Testimony of JP01 regarding
the Balancing Reserve Quantity Capacity Forecast.

Section 2: Balancing Reserve Quantity Capacity Forecast

*Q. Did any parties raise issues with the Balancing Reserve Quantity Capacity Forecast in the
Initial Proposal?*

A. Yes. Joint Party 01 (JP01) argues that BPA only needs to hold enough balancing reserve
capacity to comply with the North American Electric Reliability Corporation (NERC)
Reliability Standard BAL-001-2. According to JP01's analysis, this results in a balancing
reserve capacity requirement of 117.81 megawatts (MW) incremental reserves (INC)
and 227.50 MW decremental reserves (DEC) compared to the 705 MW INC and 852 MW
DEC balancing reserve requirement we set forth in our Initial Proposal. Tilghman &
Goggin, BP-22-E-JP01-01, at 25.

1 Q. *How do you respond to JP01's proposed methodology?*

2 A. We disagree strongly with JP01's proposed methodology. Our proposed methodology
3 reflects the realities of how BPA actually operates its balancing authority area (BAA),
4 whereas JP01's proposed methodology does not. BPA's operational decisions are not
5 rate case issues, but it is necessary to explain these operational parameters in order to
6 show why JP01's proposed methodology is so problematic.

7 JP01 cherry-picks a single requirement from one reliability standard,
8 Requirement 2 from BAL-001-2, to base its analysis on, but ignores other requirements.
9 In addition, JP01 fails to consider the effect that allowing Area Control Error (ACE) to
10 deviate will have on system frequency for the entire Western Interconnection. In short,
11 JP01's proposed methodology would both jeopardize reliability and lead to frequent use
12 of Operational Controls for Balancing Reserves (OCBR) or potentially other measures
13 impacting all resources in the BAA to maintain reliability.

14 Q. *Please explain how JP01 ignores other requirements from NERC Reliability Standard*
15 *BAL-001-2.*

16 A. JP01 claims that they "calculate the actual level of balancing reserves BPA needs to
17 comply with the relevant NERC standard," and that "[their] analysis indicates that BPA
18 could still fully comply with NERC's BAL-001-2 standard." *Id.* JP01's analysis only
19 considers Requirement 2 of BAL-001-2, the Balancing Authority Area Control Error Limit
20 (BAAL), but did not consider Requirement 1 of BAL-001-2, Control Performance
21 Standard 1 (CPS1). The chart provided in JP01's own testimony shows CPS1 limits
22 plotted in blue, and those limits are much stricter than those of BAAL. *Id.* at 27.
23 Therefore, if we adopted JP01's methodology, BPA would be unable to comply with the
24 stricter CPS1.

1 Q. Please explain the impacts JP01's proposed methodology would have on system
2 frequency.

3 A. JP01 asserts that BPA can hold a small amount of balancing reserves because (1) the
4 BAAL set under NERC Reliability Standard BAL-001-2 is so lenient when frequency is
5 close to 60 hertz (Hz) and (2) the Western Interconnect frequency is nearly always close
6 to 60 Hz. *Id.* These assumptions are incorrect; the main reason Western
7 Interconnection frequency is nearly always close to 60 Hz is because most balancing
8 authorities (BAs) operate more stringently than just meeting minimal compliance with
9 the BAAL requirement. For instance, many BAs in the region impose their own limit on
10 top of the BAAL in the near-60 Hz range to avoid having to correct for extremely large
11 ACE when frequency drifts away from 60 Hz. Also, as JP01 points out, the BAAL portion
12 of the BAL-001-2 standard requires 100 percent compliance, so BAs generally aim to
13 both return well below the limits set by BAAL and well before the 30-minute timer runs
14 out. *See id.* at 26.

15 Further, JP01's proposed methodology rests on the assumption that error in the
16 BPA BAA has limited impact to system frequency. BPA's impact on Western
17 Interconnection frequency normally ranges between 800 MW/0.1 Hz and
18 1000 MW/0.1 Hz. For instance, if BPA had an area control error between -800 MW
19 and -1000 MW, frequency would shift down to 59.9 Hz, resulting in a much tighter ACE
20 limit when error in the BAA is high. This relationship of high error (and thus high ACE)
21 and tighter ACE limit, not reflected in JP01's analysis, would result in a much higher
22 reserve requirement to ensure 100 percent compliance with the requirement. In fact,
23 BPA previously reflected its expected frequency impact and operational control
24 mechanism for BAAL in its balancing reserve study and, as noted by JP01, found much
25 more modest reserve reductions than those calculated in JP01's analysis. *Id.* at 29.

1 Thus, to appropriately calculate the BAAL, it is necessary to reflect the expected shift in
2 frequency due to error in the BAA.

3 Q. *Is there anything else you would like to add regarding JP01's proposed methodology?*

4 A. Yes, it is worth emphasizing that BAs are responsible for maintaining system reliability,
5 and while performance standards inform BAs on their ability to do so, it is up to each BA
6 to determine how best to ensure reliability. As far back as 2010, BPA moved to
7 controlling reserve deployments based on compliance with BAAL, participating in the
8 Western Electricity Coordinating Council (WECC) reliability-based control (RBC) field trial
9 until the official implementation of the BAAL requirement in BAL-001-2 (though BPA
10 maintained its planning standard-based reserve requirement). However, as of the
11 summer of 2018, BPA no longer operates on "BAAL control" for various reasons,
12 including reliability concerns and operational impacts, and has moved back to its
13 previous control mechanism ("tight control"), under which we exceed both
14 requirements of BAL-001-2 (BAAL and CPS1). The purpose of the balancing reserve
15 capacity forecast is to produce a forecast that most accurately reflects the realities of
16 BPA's system, including both the expected error and the way in which BPA operates to
17 correct that error. If BPA adopted JP01's methodology, BPA could not operate its BAA in
18 accordance with its operational practices.

19 Q. *Are there additional flaws in the methodology presented by JP01?*

20 A. Yes. JP01's proposed methodology also fails to account for several factors that BPA
21 includes in its analysis. These factors include: (1) changes to generation and load in the
22 BPA BAA for the BP-22 rate period; (2) changes to scheduling practices for the BP-22
23 rate period; (3) impacts of different weather regimes on the variability of load and solar
24 and wind generation; and (4) corrections for known irregularities in the historical data.

25 First, JP01's methodology only uses raw historical data and fails to model
26 changes in generation and load for the rate period, including the changes in solar and

1 wind generation capacity. Modeling of generation needs to include both the removal of
2 historical generation that is no longer part of the BPA BAA and modeling of new
3 generation in the BPA BAA. The impacts of these changes would be felt in all aspects of
4 JP01's analysis, altering the historical values of BPA's ACE, balancing reserves deployed
5 and system frequency. BPA captures all of these impacts on generation and load
6 through implementation of the modeling methodologies. See Generation Inputs Study,
7 BP-22-E-BPA-06, at 8-19. BPA forecasts 200 MW solar and 470 MW wind generation to
8 come online by the end of the BP-22 rate period, above and beyond the historical
9 generation captured in the data set. See Generation Inputs Study Documentation,
10 BP-22-E-BPA-06A, Table 2.1. Furthermore, BPA accounts for load growth (or decline)
11 through scaling of the historical load. Generation Inputs Study, BP-22-E-BPA-06,
12 at 18-19. All of these changes to the topology of the BPA BAA have influential impacts
13 on the variability BPA will experience in the rate period and need to be accurately
14 accounted for in the balancing reserve capacity forecast.

15 Second, JP01's analysis fails to account for the changes in scheduling behaviors
16 for the BP-22 rate period. The historical data reflects solar and wind scheduling
17 elections that will not be available in BP-22, including all persistence scheduling
18 elections and BPA's solar "matrix" scheduling option. See Fredrickson *et al.*,
19 BP-22-E-BPA-29, at 8. BPA's methodology allows BPA to remove these obsolete
20 scheduling practices, substituting the proper scheduling behaviors and/or more
21 accurate proxies. In addition, BPA's methodology allows for BPA to properly model the
22 BP-22 load scheduling practices that BPA anticipates for the rate period. See Generation
23 Inputs Study, BP-22-E-BPA-06, at 19-20. Absent the changes implemented by BPA to
24 address future scheduling practices, JP01's historical dataset inaccurately portrays the
25 variability forecasted for the BP-22 rate period.

1 Third, JP01 suggests relying on just a single year of historical data. JP01 asserts
2 that a large amount of wind generation left the BPA BAA in December 2017 and
3 July 2018, likely reducing the amount of required balancing reserves. Tilghman &
4 Goggin, BP-22-E-JP01-01, at 29. What JP01 fails to consider is a significant portion of
5 that generation participated in the Customer Served Generation Imbalance program,
6 under which reserves were self-supplied, making the impact to reserves upon their
7 departure minimal. Thus, the earlier five years should not be dismissed on that basis.
8 The wide range of values produced by JP01's methodology over the six-year period
9 highlights why a multi-year data set is necessary to calculate the required balancing
10 reserve capacity. Focusing on a single year of data fails to capture multiple seasons of
11 varying weather regimes, climatological phenomenon, and seasonal fluctuations,
12 including all of their impacts on the time-synchronized variability of load and generation
13 of all types in the BAA. BPA's use of six full years of historical data captures all of these
14 variations.

15 Lastly, JP01 failed to properly correct for irregularities in the historical data.
16 These irregularities include periods of OCBR generation limitations, oversupply
17 management, and contingency reserve deployments. These irregularities impact ACE,
18 frequency and balancing reserves deployed to various degrees. Impacts of these
19 irregularities would be difficult to accurately remove from ACE and frequency data (data
20 points which are used by JP-01 and not used in BPA's methodology). BPA's
21 methodology accounts for these impacts by correcting periods of irregularities at the
22 resource level, dramatically increasing the accuracy of BPA results. Generation Inputs
23 Study, BP-22-E-BPA-06, at 9-17.

1 Q. *How do you respond to JP01's assertion that its proposed methodology has been used in*
2 *other rate cases? Tilghman & Goggin, BP-22-E-JP01-01, at 30-31.*

3 A. Both cases cited by JP01 ended in black box settlements. While we have no reason to
4 question that Mr. Goggin advocated for this methodology in other rate cases and it
5 appears the settled rate decreased from what was initially proposed, we cannot tell
6 whether those cases actually adopted JP01's proposed methodology or any portion of it.
7 Of note, PacifiCorp's initial proposal, which JP01 claims used a similar methodology,
8 resulted in an INC balancing reserve estimate of 654 MW, significantly higher than the
9 117 MW suggested by Mr. Goggin, and on a system with similar levels of load and
10 generation. *PacifiCorp*, FERC Docket No. ER17-219-000, Tariff Filing, Attachment D,
11 Ex. No. PAC-14, at 31, Table 3 (Oct. 28, 2016).

12 Q. *Did JP01 point out any other issues with your Initial Proposal?*

13 A. Yes. JP01 also asserts that we made the following errors in our proposed methodology:
14 1) arbitrary use of the 99.7 percent planning standard; 2) failure to improve wind
15 forecast accuracy over time; 3) failure to properly account for times of OCBR or
16 oversupply limitations; 4) assumption of a perfect correlation between a future wind
17 plant and existing wind plants; 5) failure to account for improved wind plant technology;
18 6) failure to account for the diversity benefits of joining the EIM; and 7) including the
19 cost of all power purchases in the capacity cost charged to Generation Inputs. *Tilghman*
20 *& Goggin, BP-22-E-JP01-01, at 33-45.*

21 Q. *How do you respond to JP01's assertions regarding BPA's use of the 99.7 percent*
22 *planning standard for calculating balancing reserve needs?*

23 A. JP01 argues that the 99.7 percent planning standard is no longer needed because under
24 NERC Reliability Standard BAL-001-2, BPA can exclude more deviations without violating
25 the BAAL for more than 30 minutes. *Id.* at 34-35. As stated previously, JP01's narrow

1 focus on compliance with Requirement 2 of BAL-001-2 is flawed, because it does not
2 account for CPS1 and other realities of operating a BAA.

3 Moreover, BPA sets reserves using the 99.7 percent planning standard to
4 maintain system reliability and comply with NERC standards, while limiting the need to
5 use reliability tools such as OCBR. As part of the TC-20 settlement, BPA established
6 Schedule 10 to its Tariff, which provided for a Balancing Reserve Capacity Business
7 Practice to forecast the capacity needed to provide generator balancing services. The
8 Balancing Reserve Capacity Business Practice provides the 99.7 percent planning
9 standard for the calculation of balancing reserve capacity, and establishes the use of
10 OCBR "to manage balancing error events not covered by the 99.7 percent planning
11 standard." Balancing Reserve Capacity Business Practice § C.1, *available at*
12 [https://www.bpa.gov/transmission/Doing%20Business/bp/tbp/Balancing-Reserve-](https://www.bpa.gov/transmission/Doing%20Business/bp/tbp/Balancing-Reserve-Capacity-BP.pdf)
13 [Capacity-BP.pdf](https://www.bpa.gov/transmission/Doing%20Business/bp/tbp/Balancing-Reserve-Capacity-BP.pdf). OCBR provides physical relief of balancing error on the BPA system,
14 while allowing resources to save costs and BPA to hold less reserves to maintain
15 reliability and compliance. Holding less than the 99.7 percent planning standard would
16 subject customers to larger and more frequent use of OCBR.

17 Q. *How do you respond to JP01's assertion that your methodology failed to account for*
18 *improved wind forecast accuracy over time?*

19 A. We do not see any direct evidence provided by JP01 showing that improved wind
20 forecasts justify making any adjustments for this rate period. As an initial matter, we
21 must correct JP01's claim that "BPA's assumed wind forecast accuracy for the
22 FY 2022-23 rate period will be based on actual wind forecast accuracy nearly a decade
23 earlier." Tilghman & Goggin, BP-22-E-JP01-01, at 35. The wind forecasts used in BPA's
24 balancing reserve capacity forecast were produced in the proceeding hour for the given
25 hour of the forecast, so the forecasts used represent the forecasting methodology used
26 at that given point in history. For example, while forecasts for the first hour of the six-

1 year data set represent the forecasting methodology used in October 2013, forecasts for
2 the last hour of the six-year data set represent the forecasting methodology used in
3 September 2019 (two years prior to the start of the forecast rate period and only six
4 months prior to when the balancing reserve capacity forecast analysis was run).

5 As to JP01's claims that our analysis did not account for improvements in wind
6 forecasting accuracy, we do not see any evidence of such improvements at this time.
7 JP01 does not point to any specific improvements or explain how we should incorporate
8 forecasting improvement into our analysis. JP01 cites, without explanation, a paper
9 from the National Renewable Energy Laboratory (NREL), as an example. *Id.* at 36, n.64.
10 Upon review of this paper, BPA does not agree that it shows relevant improvement from
11 the forecast model addressed in the paper. Interestingly, the paper compared a
12 baseline and a proposed forecast methodology applied to BPA's aggregate wind fleet,
13 analyzing results for the months of April 2016, July 2016, October 2016, and January
14 2017. Tilghman & Goggin, BP-22-E-JP01-01-AT02, at 104. The paper itself notes that "in
15 general, small improvements [in error metrics] are seen in winter and fall but some
16 degradations are noticeable in spring and summer." *Id.* If we focus specifically on the
17 forecast errors displayed in the paper associated with the one-hour out forecasts (as are
18 used in BPA's balancing reserve capacity forecast study), we see inconsistent results
19 with an improvement in one month, virtually no changes in two months, and
20 degradation in the other month.

21 Q. *While you state there is no evidence of wind forecasting accuracy improvements at this*
22 *time, could there be improvements in the future?*

23 A. Yes, of course. Technology and techniques are always improving, and there may be
24 changes to forecasting methodology over the length of our rate case data sets that
25 could impact the balancing reserve calculation. BPA is always open to considering
26 updates to its methodology, and working with its wind forecasting vendor on the


1 feasibility of reflecting forecast improvements in BPA's balancing reserve capacity
2 forecast study.

3 Q. *Do you agree with JP01 that you did not properly account for times of OCBR or*
4 *oversupply limitations?*

5 A. No. JP01 argues that BPA should not replace times of OCBR or oversupply limitations
6 with estimated wind data because BPA will use these tools in the future, and the altered
7 output of wind generation captured in the historical data more accurately reflects future
8 wind generation. Tilghman & Goggin, BP-22-E-JP01-01, at 36-37. However, if BPA did
9 not replace these periods with estimated wind generation, it would not capture the full
10 variability of wind, and planned reserves would thus not meet the 99.7 percent planning
11 standard. *See Puyleart et al.*, BP-22-E-BPA-24, at 13-14.

12 In accordance with the Balancing Reserve Capacity Business Practice, BPA uses
13 the 99.7 percent planning standard to establish the balancing reserve capacity
14 requirement, and uses OCBR to manage balancing error events not covered by the
15 99.7 percent planning standard. For instance, considering the impacts of OCBR, the
16 99.7 percentile of an already mitigated data set with 0.3 percent outliers discarded is
17 approximately 99.4 percentile coverage of original unmitigated data. As a result,
18 99.4 percentile coverage would result in more frequent OCBR events of increased
19 magnitude, impacting all customers of the BPA BAA. Figure 1 below illustrates the
20 impact of JP01's proposal regarding OCBR data mitigation would have on BPA's planned
21 reserves.

Figure 1: Standard bell curve representing BPA's 99.7 % planning standard coverage and the reduced coverage of discarding 0.3 % outliers twice to the same data set.



Conversely, oversupply pushes wind generation below forecasted output, creating significantly more error in the wind generation than would occur from its unaltered output, which would cause BPA's balancing reserve forecast to exceed the 99.7 percent planning standard. Thus, failing to mitigate for OCBR and oversupply generation limitations in the dataset would result in BPA failing to provide the planning standard as established.

JP01's own proposal recognizes the need to correct data for OCBR and oversupply events. JP01 removes a period of OCBR and oversupply from their analysis as "[i]t appears that the *inc* reserve deployment indicated in the data coincided with a large curtailment of wind generation due to oversupply mitigation and [OCBR] limits." Tilghman & Goggin, BP-22-E-JP01-01, at 32. While JP-01 identifies the period of data based on a large deployment of balancing reserves, they justify removing and replacing the data due to BPA's OCBR and oversupply impacts.

Q. What about JP01's assertions about correlating future wind plants with existing wind plants? Do you agree?

A. No. JP01 claims that "BPA's assumption [that two wind plants are perfectly correlated]

1 overstates the correlation between the output of two wind plants, and thus understates
2 the reduction in total wind fleet variability from adding new geographically diverse wind
3 resources.” *Id.* at 37. JP01 fails to justify its claim although it tries to support it by citing
4 a paper from the NREL, quoting the following passage:

5
6 A common error [in wind and solar integration studies] is to scale the
7 output of an existing generator to represent the expected output of a
8 larger fleet. This greatly overstates the variability of wind and likely
9 overstates the variability of solar . . . It is similarly inappropriate to simulate
10 a new wind plant simply by time delaying or advancing the output of an
11 existing plant based on prevailing wind speed and direction.

12 *Id.* at 38 (quoting M. Milligan *et al.*, NREL Cost Causation and Integration Cost Analysis
13 for Variable Generation, 27 (2011) (“Milligan Paper”)).

14 We agree that using a single plant scaled to fleet size does not capture
15 geographic diversity, which is, in fact, part of the reason BPA developed both the wind
16 and solar data synthesis methodologies used in BPA’s balancing reserve capacity
17 forecast. However, we do not agree that it is inappropriate to simulate a new plant by
18 the time-shifting of an existing plant. BPA found that the *Milligan Paper* provides no
19 evidence in support of this claim. In fact, the *Milligan Paper* cites another NREL
20 publication that compares two plants 200 kilometers (km) from each other, which finds
21 high correlation when one plant is time-shifted relative to the other. Wan, Y.H., *Wind*
22 *Power Plant Behaviors: Analyses of Long-Term Wind Power Data*, at 25 (2004) (“*Wan*
23 *Paper*”). The *Wan Paper* goes on to state, “[m]eteorologists can predict how fast a
24 weather front travels and when it will reach a certain point. With this knowledge and
25 knowledge of the wind power plant characteristics, the output of the downwind plant
26 can be predicted from the output power of the upwind wind power plant.” *Id.* We
27 believe this analysis undercuts the *Milligan Paper*’s claim.

28 JP01 also references another publication, asserting that “50 miles (approximately

1 80 kilometers) is sufficient to reduce two wind plant's' hourly variability correlation to
2 less than 0.2." Tilghman & Goggin, BP-22-E-JP01-01, at 38 (*citing* H. Holttinen *et al.*,
3 *Design and Operation of Power Systems with Large Amounts of Wind Power: Final*
4 *Report, IEA WIND Task 25, Phase Three 2006-2008*, at 25 (2009) ("*Holttinen Paper*").
5 Review of the *Holttinen Paper* reveals, however, that the figure presented does not
6 include any time-shifting, and thus lacks any direct comparison to BPA's methodology.

7 Regardless of the academic publications cited by JP01, our analysis of
8 correlations used in the BP-22 balancing reserve capacity forecast yields high
9 correlations in all cases. There are four future wind plants analyzed in BPA's BP-22
10 balancing reserve capacity forecast. As a reminder, BPA uses three years of 10-minute
11 mesoscale¹ wind speed predictions across an approximately 2 km granularity grid
12 produced by NREL and 3TIER (a forecasting company now part of Vaisala), shifting them
13 in time at various intervals, to determine the most highly correlated existing plant to
14 each of the future plants at an optimal time shift. Generation Inputs Study, BP-22-E-
15 BPA-06, at 9-11. In analyzing the mesoscale wind speed information, the analysis found
16 existing plants with a wind speed correlation of 1.0 when shifted by 0 minutes for two of
17 the future plants, 0.95 when shifted by 10 minutes for one of the future plants, and 0.91
18 for the last plant when shifted by 10 minutes, and each of these four future sites is
19 located between 12 and 27 kilometers from the corresponding highest correlated
20 existing plant. BPA considers these values to indicate substantial correlation,
21 demonstrating that the outputs within hour to be extremely coupled at the associated
22 optimal time lags.

23 Further, while we cannot compare the mesoscale correlations of these plants to
24 the actual output correlations, as the four plants do not yet exist, we can consider

¹ An intermediate scale, especially that between the scales of weather systems and of microclimates, on which storms and other phenomena occur.

another similarly situated group of three plants for comparison. The North Hurlburt, South Hurlburt, and Horseshoe Bend wind plants sit at distances of 8 km to 21 km. In Table 1 below, we see that high correlations based on the mesoscale wind-speed analysis correspond with correlations between actual one-minute plant outputs that are nearly as high. While JP01 claims that “[e]ven two wind plants located several dozen miles from each other have very low correlation in the sub-hourly output variability . . .,” Tilghman & Goggin, BPA-22-E-JP01-01, at 38, our analysis shows high levels of correlation, as shown in Table 1 below.

Table 1: Correlation Comparison for select BPA Wind Projects

	Distance (km, approx.)	Mesoscale Data Corr.	Real Output Corr.
N. Hurlburt – S. Hurlburt	8	1.0 (0 min. shift)	0.9644 (0 min. shift)
N. Hurlburt – Horseshoe Bend	27	0.9966 (0 min. shift)	0.9210 (1 min. shift)
S. Hurlburt – Horseshoe Bend	14	0.9966 (0 min. shift)	0.9558 (0 min. shift)

Q. Do you agree with JP01’s assertion that you did not properly account for improvements in wind plant technology?

*A. No. JP01 claims that “[m]ultiple studies have documented that newer wind turbines, with longer blades and taller towers, have less variable output than older turbines, reducing the need for balancing reserves and the cost of integrating wind generation.” Id. at 40. JP01 cites to two sources in support of its claim: Ryan H. Wiser et al., *The Hidden Value Of Large-Rotor, Tall-Tower Wind Turbines In The United States Electricity Markets & Policy* (2020) (“Wiser Paper”); Lion Hirth & Simon Muller, *Energy Economics, System-Friendly Wind Power: How Advanced Wind Turbine Design Can Increase The Economic Value Of Electricity Generated Through Wind Power*, *Energy Economics* (2016) (“Hirth & Muller Paper”). Upon review of these sources, BPA does not see compelling evidence of reduction in wind plant error and subsequent reduction in balancing reserve*

1 need. In fact, one cited source states:

2 Large errors and ramps increase the amount of balancing reserves
3 needed to maintain grid operations in real time. The steeper power
4 curve of low-SP, tall-tower turbines can increase the size of large forecast
5 errors and ramps. However, by spreading these balancing costs across a
6 greater amount of generation [energy], such turbines may result in lower
7 balancing costs on a US\$/MWh basis.

8 Wiser Paper at 5. In other words, these wind plant technologies do result in more
9 balancing error than previous turbine generations, but the associated increase in
10 capacity factor means that generator owners will make up for the cost of those reserves
11 with the additional energy captured.

12 Another source cited by JP01 only uses three-hour time granularity data, which is
13 inappropriate to capture reserve requirements from within the hour, and explicitly
14 states that “the primary focus of [this] study is not an assessment of balancing
15 requirements . . .” Hirth & Muller Paper at 7. Further, the authors recognize a similar
16 concept to the *Wiser Paper*, suggesting that while aggregate wind forecasts may
17 decrease (assuming the higher capacity factor of newer turbine designs reduces the
18 installed capacity need), the steeper power curve of the new designs results in increased
19 forecast error on an individual plant basis. *Id.* at 20. BPA’s balancing reserve capacity
20 analysis uses wind forecasts on an individual plant basis since they represent individual
21 plant schedules; therefore, accounting for improvements in wind plant technology in
22 the way JP01 suggests may actually increase balancing reserve capacity requirements.

23 Q. *Review of JP01’s sources seems to suggest that newer technology could actually increase*
24 *balancing reserve requirements. Should BPA increase balancing reserve capacity*
25 *associated with new wind turbine technologies?*

26 A. No. BPA has little indication of how much and when wind plants in BPA’s BAA will
27 incorporate new wind turbine technologies and what impacts will be realized when or if
28 they do. While an increase in balancing reserve capacity due to new wind technology is

1 plausible, BPA lacks site specific data to calculate the diversified impacts new wind
2 technology would have on the BPA BAA.

3 Q. *How do you respond to JP01's assertion that you did not account for the diversity*
4 *benefits of joining the EIM?*

5 A. We have no basis at this time to account for any diversity benefits for EIM participation.
6 First, the EIM is an energy imbalance optimization market and assumes no responsibility
7 for the reliability obligations of a participating BA, including capacity needed for
8 compliance with NERC Reliability Standards, such as BAL-001-2. Puyleart *et al.*,
9 BP-22-E-BPA-24, at 3. The EIM is not a capacity or ancillary services market. Each BA
10 participating in the EIM retains all responsibility to maintain reliability through real-time
11 balancing of generation, load, and interchanges. This is especially true during times
12 when BPA is not in the market or limited in participating, which are largely beyond the
13 BA's control, such as if BPA does not pass the resource sufficiency tests or there are
14 insufficient transmission donations. As a result, if BPA joins the EIM, BPA will have the
15 same capacity requirement to hold enough balancing reserve capacity to meet its BA
16 obligations.

17 Second, while other BAs may provide some diversity benefit from EIM
18 participation, as JP01 asserts, BPA has no basis to do so at this time. See Tilghman &
19 Goggin, BP-22-E-JP01-01, at 44. BPA will reevaluate the required balancing reserve
20 capacity in light of EIM participation in future rate cases, once experience is gained. If
21 BPA is able to operationally take advantage of a diversity benefit, then we will work to
22 incorporate that benefit into our analysis.

23 Lastly, we must respond to JP01's assertion that joining the EIM is a net harm for
24 Variable Energy Resources (VER). While BPA does propose removing the persistence
25 scheduling options due to EIM scheduling timelines, the ultimate impact only negatively
26 effects VERs that schedule on a 15-minute basis. BPA has a limited number of Variable

1 Energy Resource Balancing Service (VERBS) customers that have elected to schedule on
2 a 15-minute basis. For all other VERBS customers, there is actually a net reduction in
3 VERs balancing reserve capacity relative to BP-20 because of our updates to forecast
4 scheduling, and their rate for VERBS is decreasing. Thus, we disagree that joining the
5 EIM has resulted in a detrimental impact to VERs.

6 Q. *Finally, how do you respond to JP01's assertion that you improperly included the costs of*
7 *all capacity purchases in Generation Inputs?*

8 A. This issue is beyond the scope of the Balancing Reserve Quantity Forecast, and is
9 addressed in Ramse *et al.*, BP-22-E-BPA-40, § 2.

10 Q. *Does this conclude your testimony?*

11 A. Yes.

